

ABB BALDOR RELIANCE III

Customer information packet

ECP4412T-4

125HP, 3570RPM, 3PH, 60HZ, 444TS, A4468M, TEFC

Class - CLI GP A,B,C,D

Division - Division II

Specifications

Enclosure	TEFC
Frame	444TS
Frame Material	Iron
Frequency	60.00 Hz
Haz Area Class and Group	CLI GP A,B,C,D
Haz Area Division	Division II
Motor Letter Type	Three Phase
Output @ Frequency	125.000 HP @ 60 HZ
Phase	3
Synchronous Speed @ Frequency	3600 RPM @ 60 HZ
Voltage @ Frequency	460.0 V @ 60 HZ
Agency Approvals	CCSAUSEEV
Ambient Temperature	40 °C
Auxiliary Box	NO AUXILLARY BOX
Base Indicator	Rigid
Bearing Grease Type	Polyrex EM (-20F +300F)
Constant Torque Speed Range	15-60
Current @ Voltage	137.000 A @ 460.0 V
Design Code	B
Drip Cover	No Drip Cover
Duty Rating	CONT
Efficiency @ 100% Load	95.0 %
Feedback Device	NO FEEDBACK
Haz Area Temp Code	T3
Heater Indicator	No Heater
High Voltage Full Load Amps	137.0 a
Insulation Class	F
Inverter Code	Inverter Ready
KVA Code	F
Lifting Lugs	Standard Lifting Lugs
Motor Lead Quantity/Wire Size	6 @ 2 AWG
Motor Standards	NEMA

Part Detail

Revision	Y
Type	AC
Mech. spec.	
Base	
Status	PRD/A
Elec. spec.	A44WG3534
Layout	617427-493
Eff. date	03-17-2026
CD Diagram	416820-036
Poles	02
Leads	3#2 (02 per group)
Proprietary	False
Created date	08-16-2012

Motor Type	A4468M
Mounting Arrangement	F1
Number of Poles	2
Overall Length	40.83 IN
Power Factor	89
Pulley End Bearing Type	Ball
Pulley Face Code	Standard
Service Factor	1.15
Shaft Diameter	2.375 IN
Shaft Ground Indicator	No Shaft Grounding
Shaft Rotation	Reversible
Shaft Slinger Indicator	Shaft Slinger
Speed	3570 rpm
Speed Code	Single Speed
Starting Method	Direct on line
Thermal Device - Bearing	None
Thermal Device - Winding	None

Nameplate

NP3238													
CAT NO	ECP4412T-4			SPEC NO.		P44G3943							
HP	125	AMPS	137	VOLTS		460			DESIGN	B			
FRAME	444TS	RPM	3570	HZ	60	AMB	40	SF	1.15				
D.E. BRG.DATA	6313	O.D.E. BRG.DATA			6313	PH	3	DUTY	CONT	INSUL.CLASS	F		
D.E. BRG.	65BC03J30X			TYPE	P	ENCL	TEFC	CODE	F				
O.D.E. BRG.	65BC03J30X			POWER FACTOR			89	NEMA NOM EFFICIENCY			95		
3/4 LOAD EFF.	95.5	MAX CORR KVAR			18.0	GUARANTEED EFFICIENCY			94.1				
TEMP CODE	T3	TEMP =	200										
CHP HZ	60-75	CT HZ	15-60	VT HZ	0-60								
INVERTER-TEMP-CODE	T3												
SER.NO.				MOTOR WEIGHT									

REL. S.O.	FRAME	HP	TYPE	PHASE/ HERTZ	RPM	VOLTS
	444TS	125	P	3/60	3570	460
AMPS	DUTY	AMB °C/ INSUL.	S.F.	NEMA DESIGN	CODE LETTER	ENCL.
137	CONT	40/F	1.15	B	F	TEFC
E/S	ROTOR	TEST S.O.	TEST DATE	STATOR RES. @25 °C OHMS (BETWEEN LINES)		
-	418143-8-RE	---	---	.0343		
PERFORMANCE						
LOAD	HP	AMPERES	RPM	% POWER FACTOR	% EFFICIENCY	
NO LOAD	0	30.4	3600	7.45	0	
1/4	31.3	51.0	3593	62.3	92.1	
2/4	62.5	76.5	3585	80.7	94.9	
3/4	93.8	106	3578	87.1	95.5	
4/4	125	137	3570	89.3	95.4	
5/4	156	171	3562	89.9	95.0	
SPEED TORQUE						
		RPM	TORQUE % FULL LOAD	TORQUE LB.-FT.	AMPERES	
LOCKED ROTOR		0	125	229	873	
PULL UP		288	102	187	804	
BREAKDOWN		3461	277	509	456	
FULL LOAD		3570	100	184	137	
AMPERES SHOWN FOR 460. VOLT CONNECTION. IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE REMARKS: TYPICAL DATA						
		DR. BY	J. TSAO	A-C MOTOR PERFORMANCE DATA		
		CK. BY	T. KELATI			
		APP. BY	T. KELATI			
		DATE	08/10/11			
				A44WG3534-R001 ISSUE DATE 04/05/21		

REL S.O.

 RPM **3570**

 S.F. **1.15**

 ROTOR **418143-8-RE**

 FRAME **444TS**

 VOLTS **460**

 NEMA DESIGN **B**

 TEST S.O. **TYPICAL DATA**

 HP **125**

 AMPS **137**

 CODE LETTER **F**

 TEST DATE **---**

 TYPE **P**

 DUTY **CONT**

 ENCLOSURE **TEFC**


 STATOR RES. @ 25 °C **.0343**

 PHASE/HERTZ **3/60**

 AMB °C/INSUL **40/F**

 E/S **-**

OHMS (BETWEEN LINES)



AMPERES SHOWN FOR 460 VOLT CONNECTION, IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE.

BALDOR
A MEMBER OF THE ABB GROUP


DR. BY J. TSAO
CK. BY T. KELATI
APP. BY T. KELATI
DATE 08/10/11

**A-C MOTOR
PERFORMANCE
CURVES**

A44WG3534-R001

ISSUE DATE 04/05/21 Page 6 of 10

REL. S.O.	RPM 3570	S.F. 1.15	ROTOR 418143-8-RE
FRAME 444TS	VOLTS 460	NEMA DESIGN B	TEST S.O. TYPICAL DATA
HP 125	AMPS 137	CODE LETTER F	TEST DATE ---
TYPE P	DUTY CONT	ENCLOSURE TEFC	STATOR RES. @ 25 °C .0343
PHASE/HERTZ 3/60	AMB °C/INSUL 40/F	E/S -	OHMS (BETWEEN LINES)



THERMAL LIMIT CURVE

REMARKS:

AMPERES SHOWN FOR 460 VOLT CONNECTION, IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE.




DR. BY	J. TSAO
CK. BY	T. KELATI
APP. BY	T. KELATI
DATE	08/10/11

**A-C MOTOR
PERFORMANCE
CURVES**


A44WG3534-R001

ISSUE DATE **04/05/21** Page 7 of 10



416820-036

A-C MOTOR
CONNECTION DIAGRAM
STANDARD 3 LEAD CONNECTED



(N.P. 1575-BA)

416820-036

REV. DESC: LOADED TO BUS, C/R 335225		
REV. LTR: -	VERSION: 00	TDR: 000000538207
FILE: \MGA\00000\682	REVISED: 11: 54: 06 04/30/2010	
MTL: -	BY: RAGRA	

BALDOR

CONN DIAG - STANDARD 3 LEAD
SH 1 of 1