

ABB BALDOR RELIANCE III

Customer information packet

EM25452T-4

450HP, 3570RPM, 3PH, 60HZ, 449TS, DP, F1

Class - None

Division - Not Applicable

Specifications

Enclosure	DP
Frame	449TS
Frame Material	Iron
Frequency	60.00 Hz
Haz Area Class and Group	None
Haz Area Division	Not Applicable
Motor Letter Type	Three Phase
Output @ Frequency	450.000 HP @ 60 HZ
Phase	3
Synchronous Speed @ Frequency	3600 RPM @ 60 HZ
Voltage @ Frequency	460.0 V @ 60 HZ
Agency Approvals	CURUSEEV
Ambient Temperature	40 °C
Auxiliary Box	NO AUXILLARY BOX
Base Indicator	Rigid
Bearing Grease Type	Polyrex EM (-20F +300F)
Current @ Voltage	494.000 A @ 460.0 V
Design Code	B
Drip Cover	No Drip Cover
Duty Rating	CONT
Efficiency @ 100% Load	96.2 %
Feedback Device	NO FEEDBACK
Heater Indicator	No Heater
High Voltage Full Load Amps	494.0 a
Insulation Class	F
Inverter Code	Inverter Ready
IP Rating	NONE
KVA Code	F
Lifting Lugs	Standard Lifting Lugs
Motor Lead Quantity/Wire Size	12 @ 1 AWG
Motor Standards	NEMA
Motor Type	A44112M

Part Detail

Revision	B
Type	AC
Mech. spec.	
Base	
Status	PRD/A
Elec. spec.	A44WG2693
Layout	604989-595
Eff. date	07-18-2022
CD Diagram	416820-008
Poles	02
Leads	6#1 (02 per group)
Proprietary	False
Created date	11-23-2015

Mounting Arrangement	F1
Number of Poles	2
Overall Length	44.31 IN
Power Factor	88
Product Family	General Industrial
Pulley End Bearing Type	Ball
Pulley Face Code	Standard
Service Factor	1.15
Shaft Diameter	2.375 IN
Shaft Ground Indicator	No Shaft Grounding
Shaft Rotation	Reversible
Shaft Slinger Indicator	No Slinger
Speed	3570 rpm
Speed Code	Single Speed
Starting Method	Wye Start - Delta Run
Thermal Device - Bearing	None
Thermal Device - Winding	None

Nameplate


NP2496L	
MOBIL POLYREX EM	

NP2349L

SPEC NO.	A44-8054-2693			CAT.NO.	EM25452T-4				FRAME	449TS	
HP	450	VOLTS	460	PHASE	3	DESIGN	B	TYPE	P		
RPM	3570	AMPS	494	HZ	60	AMB	40	SF	1.15		
DRIVE END BEARING	65BC03J30X		DUTY	CONT	INSUL.CLASS		F				
OPP D.E. BEARING	65BC03J30X		ENCL	DP	CODE	F					
SER.NO.				POWER FACTOR	88	NEMA-NOM-EFFICIENCY			96.2		
					MAX CORR KVAR	75	GUARANTEED EFFICIENCY			95.4	
					NEMA NOM/CSA QUOTED EFF						
					MOTOR WEIGHT						

REL. S.O.	FRAME	HP	TYPE	PHASE/ HERTZ	RPM	VOLTS		
	449T	450	P	3/60	3570	460		
AMPS	DUTY	AMB °C/ INSUL.	S.F.	NEMA DESIGN	CODE LETTER	ENCL.		
494	CONT	40/F	1.15	B	F	PRXE		
E/S	ROTOR	TEST S.O.	TEST DATE	STATOR RES. @25 °C OHMS (BETWEEN LINES)				
433499	418143013KE	---	---	.00760				
PERFORMANCE								
LOAD	HP	AMPERES	RPM	% POWER FACTOR	% EFFICIENCY			
NO LOAD	0	124	3600	4.41	0			
1/4	113	170	3593	65.6	94.5			
2/4	225	263	3586	83.2	96.3			
3/4	337	374	3578	87.4	96.5			
4/4	450	494	3570	88.4	96.3			
5/4	562	618	3561	88.8	95.9			
SPEED TORQUE								
		RPM	TORQUE % FULL LOAD	TORQUE LB.-FT.	AMPERES			
LOCKED ROTOR		0	198	1310	2870			
PULL UP		2550	161	1064	2300			
BREAKDOWN		3472	213	1409	1539			
FULL LOAD		3570	100	661	494			
AMPERES SHOWN FOR 460. VOLT CONNECTION. IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE REMARKS: CALCULATED DATA XE MOTOR, NEMA NOM. EFF. 96.2%								
		DR. BY	J. J. HARRISON	A-C MOTOR PERFORMANCE DATA				
		CK. BY	W. L. SMITH					
		APP. BY	W. L. SMITH					
		DATE	01/21/2010					
			A44WG2693-R001 ISSUE DATE 01/21/20					

REL S.O.	RPM 3570	S.F. 1.15	ROTOR 418143013KE
FRAME 449T	VOLTS 460	NEMA DESIGN B	TEST S.O. CALCULATED DATA
HP 450	AMPS 494	CODE LETTER F	TEST DATE ---
TYPE P	DUTY CONT	ENCLOSURE PRXE	STATOR RES. @ 25 °C .00760
PHASE/HERTZ 3/60	AMB °C/INSUL 40/F	E/S 433499	OHMS (BETWEEN LINES)




AMPERES SHOWN FOR 460 VOLT CONNECTION, IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE.

BALDOR
A MEMBER OF THE ABB GROUP

DR. BY J.J. HARRISON
CK. BY W.L. SMITH
APP. BY W.L. SMITH
DATE 01/21/2010

**A-C MOTOR
PERFORMANCE
CURVES**



A44WG2693-R001
ISSUE DATE 01/21/2010



416820-008

A-C MOTOR
CONNECTION DIAGRAM

STANDARD 6 LEAD Y START – DELTA RUN



< N. P. 1767-DC >

REV. DESC: ADDED T4 TO Y CONNECT DIAGRAM		
REV. LTR: D	VERSION: 04	TDR: 000000847713
FILE: \RAG\00001\808	REVISED: 10: 41: 26 04/08/2014	BY: RAGJSS1
MTL: -	© □	

BALDOR

CONNECT DIAGRAM STD 6 LEAD Y START DELTA RUN

SH 1 of 1

416820-008