

ABB BALDOR RELIANCE III

Customer information packet

JL1301A

.33HP, 1725RPM, 1PH, 60HZ, 56J, 3414L, OPEN, F1

Class - None

Division - Not Applicable

Specifications

Enclosure	OPEN
Frame	56J
Frame Material	Steel
Frequency	60.00 Hz
Haz Area Class and Group	None
Haz Area Division	Not Applicable
Motor Letter Type	Cap Start, Induction Run
Output @ Frequency	.330 HP @ 60 HZ
Phase	1
Synchronous Speed @ Frequency	1800 RPM @ 60 HZ
Voltage @ Frequency	115.0 V @ 60 HZ 230.0 V @ 60 HZ
Agency Approvals	UR CSA
Ambient Temperature	40 °C
Auxiliary Box	NO AUXILLARY BOX
Auxiliary Box Lead Termination	None
Base Indicator	No Mounting
Bearing Grease Type	Polyrex EM (-20F +300F)
Blower	None
Current @ Voltage	3.000 A @ 230.0 V 3.600 A @ 208.0 V 6.000 A @ 115.0 V
Design Code	N
Drip Cover	Drip Cover
Duty Rating	CONT
Efficiency @ 100% Load	60.0 %
Electrically Isolated Bearing	Not Electrically Isolated
Feedback Device	NO FEEDBACK
Front Face Code	Terminal Panel
Front Shaft Indicator	None
Heater Indicator	No Heater

Part Detail

Revision	W
Type	AC
Mech. spec.	34F036
Base	
Status	PRD/A
Elec. spec.	34WG5599
Layout	34LYF036
Eff. date	12-31-2024
CD Diagram	CD0203
Poles	04
Leads	6#18
Proprietary	False
Created date	01-01-0001

High Voltage Full Load Amps	3.0 a
Insulation Class	B
Inverter Code	Not Inverter
KVA Code	L
Lifting Lugs	No Lifting Lugs
Locked Bearing Indicator	Locked Bearing
Motor Lead Exit	Terminal Panel Or Lead Hole
Motor Lead Quantity/Wire Size	6 @ 18 AWG
Motor Lead Termination	Flying Leads
Motor Standards	NEMA
Motor Type	3414L
Mounting Arrangement	F1
Number of Poles	4
Overall Length	11.89 IN
Power Factor	60
Product Family	General Purpose
Pulley End Bearing Type	Ball
Pulley Face Code	C-Face
Pulley Shaft Indicator	Ext Thread
Rodent Screen	None
RoHS Status	ROHS COMPLIANT
Service Factor	1.35
Shaft Diameter	0.625 IN
Shaft Extension Location	Pulley End
Shaft Ground Indicator	No Shaft Grounding
Shaft Rotation	Fixed Opposite Standard
Shaft Slinger Indicator	No Slinger
Speed	1725 rpm
Speed Code	Single Speed
Starting Method	Direct on line
Thermal Device - Bearing	None
Thermal Device - Winding	None
Vibration Sensor Indicator	No Vibration Sensor
Winding Thermal 1	Automatic Thermal Overload

Winding Thermal 1 Location

SB

Nameplate

NP1257L											
CAT.NO.	JL1301A										
SPEC.	34F036-5599										
HP	.33										
VOLTS	115/230										
AMP	6/3										
RPM	1725										
FRAME	56J			HZ		60		PH		1	
SER.F.	1.35		CODE	L	DES		N	CL	B		
NEMA-NOM-EFF	60		PF	60							
RATING	40C AMB-CONT										
CC											
DE	6203		ODE		6203						
ENCL	OPEN	SN									
	SFA 6.8/3.4										

AC Induction Motor Performance Data

Record # 6787

Typical performance - not guaranteed values

Winding: 34WG5599-R001				Type: 3414L		Enclosure: OPEN	
Nameplate Data				230 V, 60 Hz: High Voltage Connection			
Rated Output (HP)		.33		Full Load Torque		1 LB-FT	
Volts		115/230		Start Configuration		direct on line	
Full Load Amps		6/3		Breakdown Torque		2.95 LB-FT	
R.P.M.		1725		Pull-up Torque		2.55 LB-FT	
Hz	60	Phase	1	Locked-rotor Torque		3.6 LB-FT	
NEMA Design Code		N	KVA Code	Starting Current		13 A	
Service Factor (S.F.)		1.35		No-load Current		2.6 A	
NEMA Nom. Eff.		60	Power Factor	Line-line Res. @ 25°C		6.32 Ω A Ph 4.93 Ω B Ph	
Rating - Duty		40C AMB-CONT		Temp. Rise @ Rated Load		43°C	
S.F. Amps		6.8/3.4		Temp. Rise @ S.F. Load		53°C	

Load Characteristics 230 V, 60 Hz, 0.33 HP

% of Rated Load	25	50	75	100	125	150	S.F.
Power Factor	31	41	51	60	66	72	70
Efficiency	34	49	56	60	62	63	63
Speed	1783	1765	1745	1730	1710	1680	1695
Line amperes	2.6	2.7	2.8	3	3.3	3.7	3.4


ABB Motors and Mechanical Inc.

WINDING # 34WG5599


Typical performance - not guaranteed values.

0.33 HP 1 PH 60 HZ 1725 RPM 230 V 3414L

TORQUES (LB-FT): PO=2.95 PU=2.55 LR=3.6 LRA=13



34LYF036



CUSTOMER IS RESPONSIBLE FOR DETERMINING THAT THE PRODUCT WILL PERFORM SUITABLY IN THE INTENDED APPLICATION

REV. DESC: CLEAN UP DIMENSIONING

REV: L VERSION: 04 REVISED: 03:37:02 08/29/2025 TDR: 000001262510

34LYF036

MODEL NO. 34LYF036

BY: ENJEFD0


REF: -

BALDOR - RELIANCE®

STD VERT 34L NEMA 56J OPEN W/DRIP COVER & TERM PLATE

34LYF036

CD0203



NOTES:

1. CONNECT LINE LEADS TO L1 AND L2.
LOW VOLTAGE: CONNECT AS SHOWN.
HIGH VOLTAGE: MOVE LEAD J TO TERM. 3.
MOVE LEAD 2 TO TERM. 4.
2. CONNECTIONS ARE SHOWN FOR STANDARD
ROTATION (CCW FACING END OPPOSITE
SHAFT EXTENSION). INTERCHANGE
5 AND 8 INTERNALLY FOR OPPOSITE
STANDARD ROTATION.
3. MULTIPLE CAPACITORS ARE CONNECTED IN
PARALLEL UNLESS OTHERWISE SPECIFIED.
4. LEAD COLORS ARE OPTIONAL. LEADS MUST
ALWAYS BE NUMBERED AS SHOWN.

REV. DESC: REMOVE MODEL 17 CONNECTION

REV. LTR: G

VERSION: 02

TDR: 000001250682

FILE: \AAA\00007\108

REVISED: 12: 29: 47 04/16/2025

BY: ENBRIRO

MTL: -



BALDOR - RELIANCE®

TYPE L, DV, FIX, THERMAL, TERMINAL PLATE

SH 1 of 1

CD0203